



Garden State Laboratories, Inc.

Report of Analysis

410 Hillside Ave.
Hillside, NJ 07205

Telephone: 800-273-8901
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
NJDEP Lab Cert. #20044

Jersey Shore Lab
NJDEP Lab Cert. #15037

Lakehurst Lab
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Manager Emerita

For: Princeton Child Development Institute
300 Cold Soil Rd.

Princeton, NJ 08540

Laboratory Director:

Attention: Nicolette Kennedy

Client Number: PRI17C

Report Date: 05/06/2025

Sample ID: Princeton Child Development
Institute - 300 Cold Soil Rd,
Princeton, NJ, 08540 - Field
Blank

Lab Sample ID: 250418006-01

Site: Collection Date/Time: 04/17/2025 07:59

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	05/01/25 14:43	

Sample ID: Princeton Child Development
Institute - 300 Cold Soil Rd,
Princeton, NJ, 08540 - Central
Kitchen Sink

Lab Sample ID: 250418006-02

Site: Collection Date/Time: 04/17/2025 08:05

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	05/01/25 14:46	

Sample ID: Princeton Child Development
Institute - 300 Cold Soil Rd,
Princeton, NJ, 08540 - South
Wing Kitchen Sink

Lab Sample ID: 250418006-03

Site: Collection Date/Time: 04/17/2025 08:08

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	05/01/25 14:49	

DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit,
MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.